

NASA
TP
1709
c.1

NASA Technical Paper 1709

LOAN COPY: F
AFWL TECHN
KIRTLAND AFB

0134887



TECH LIBRARY KAFB, NM

MARS 1414 Recorder Environmental Tests

David Langjahr

AUGUST 1980

NASA



NASA Technical Paper 1709

MARS 1414 Recorder Environmental Tests

David Langjahr
*Goddard Space Flight Center
Greenbelt, Maryland*



National Aeronautics
and Space Administration

**Scientific and Technical
Information Branch**

1980

ABSTRACT

This technical paper describes environmental testing and presents the data of the Modular Airborne Recording System (MARS) 1414. This paper is intended to be used as a tool for analysis of this recorder. The preliminary data marks a starting point for more complete thermal testing in the future. The unit was operated at the limits specified by the manufacturer (Bell and Howell), that is $\pm 55^{\circ}\text{C}$ at one atmosphere, -10°C at 75,000 feet (28mmHg) at the other. Temperatures at 13 locations on the unit were monitored and plotted against elapsed time. From the test results, some estimation can be made of ambient temperatures in which the heaters will operate and shut off. This data is sufficient to complete a preliminary analysis of the MARS 1414 Recorder, and to design further tests in which to obtain greater results and more thorough analysis.

CONTENTS

| | |
|--|----|
| INTRODUCTION | 1 |
| TEST PROCEDURE | 1 |
| COMMENTS | 1 |
| DATA SUMMARY | 3 |
| ACKNOWLEDGMENTS | 6 |
| Temperature Vs. Time -55°C, 1 ATM Ambient | 9 |
| Temperature Vs. Time +55°C, 1 ATM Ambient | 15 |
| Temperature Vs. Time -10°C, 75000' (28mm) Ambient | 21 |

MARS 1414 RECORDER ENVIRONMENTAL TESTS

David Langjahr

INTRODUCTION

A MARS 1414 tape recorder (Part #535990 Rev XI, serial 1001, Goddard #262636) was tested to the maker's specifications: Nonoperating: -55°C and $+71^{\circ}\text{C}$ and sea level to 75,000 feet; Operating: -55°C to $+55^{\circ}\text{C}$ and sea level to 75,000 feet per MIL-E-5400J, class 1, (Figure 4, Curve A) extrapolated. This curve is reproduced in Figure 1. Straight line extrapolation to 75,000 feet indicates a temperature of approximately -10°C .

TEST PROCEDURE

The unit was outfitted with 13 thermocouples (T/C's) at various locations inside and outside (see Figure 2). It was then placed in the chamber and run in the forward record mode at 1-7/8 ips for approximately four hours, with the chamber at 22°C nominal and standard pressure. A sine wave of 2 volts P-P amplitude was recorded on channels 7 and 9, while the reference oscillator signal supplied by the tape recorder was inputted to channel 8, leaving 11 channels unused.

The chamber environment was then changed to:

- -55°C , 760 mmHg (8 April 1980) for nominal 5 hours
- $+55^{\circ}\text{C}$, 760 mmHg (9 April 1980) for nominal 5 hours
- -10°C , 28 mmHg (6 May 1980) for nominal 6 hours

A summary of the data is given in Figure 2.

Infomag, who supplies tape headstacks, says the stack can "withstand" 71°C , which is apparently how the non-operating upper temperature limit was determined. During testing, this temperature was monitored to ensure that it did not exceed this limit.

During the testing, the power consumed by the recorder was nominally 56 watts at 28 volts. An internal thermostat designed to go on at 0°C and off at $+4^{\circ}\text{C}$ controls the heaters: when they are on, power consumption was an additional 280 watts, (totalling 336 watts). The heaters did not cycle at the -55°C ambient or at any time during the tests.

At the end of test, the tape was played back through the tape control unit supplied with the recorder, to check for proper operation.

COMMENTS

The tests run at one atmosphere were conducted in facility 230 (see Figure 3) in which the air is changed twice/minute. This corresponds to an airflow over the recorder of about 24 feet/minute, introducing a "chill factor" which reduces the thermal resistance (recorder case-to-ambient) an estimated 6%.




Figure 1. Operational Requirements for Class 1 Airborne Electronic Equipment (Temperature vs. Altitude)

DATA SUMMARY

| T/C Title | T/C | Final temperature rise above ambient | | | |
|--------------|-----|--------------------------------------|-------|-------|-------|
| | | Ambient = -55°C | -10°C | +22°C | +55°C |
| thermostat | A | 45 | 27 | 12 | 9.1 |
| L reel mot. | B | 50 | 37 | 19 | 15 |
| R reel mot. | C | 49 | 35 | 18 | 14 |
| internal air | D | 39 | * | 11 | 7.4 |
| headstack | E | 44 | 32 | 17 | 12 |
| top panel | F | 17 | 18 | 7.2 | 4.1 |
| bottom panel | G | 24 | 4.0 | 7.6 | 4.5 |
| bottom | H | 33 | 6.0 | 8.4 | 5.4 |
| top | I | 31 | 18 | 7.1 | 4.1 |
| right side | J | 41 | 20 | 8.5 | 5.2 |
| left side | K | 31 | 18 | 7.1 | 4.1 |
| front | L | 36 | 25 | 13 | 9.2 |
| back | M | 7.0 | 15 | 4.2 | 0.6 |
| chamber air | #14 | See graphs | | | |

Notes:

*defective thermocouple

The first five thermocouples are internal

T/C's H, I, J, K, L are on panels that are heated. These heaters were on during the -55°C test.




Figure 2. Data Summary and Recorder Configuration

FACILITY NO. 230

MFG: Guardite Company, Division of American-Marietta

CHAMBER SIZE

Nominal Working Dimensions:
Nominal Volume:

3' x 3' x 6' High (91 cm x 91 cm x 183 cm hi)
54 Cubic Feet (1.5 cu.m.)
Stainless Steel Walls
Air Flow ~120 CFM

THERMAL SYSTEM

Heat Transfer Fluid:
Temperature Range:
Thermal Control Medium:

Relative Humidity:

Heat Load Capacity:

Forced Air
-65°C to +100°C
Cooling - Cascade Freon Refrigeration F22/F13
Heating - Electric Heater (6.6 KW)
10% to 95%, Controllable; Dehumidification
by F12 Refrigeration System
2 KW

INSTRUMENTATION

Data Central:
Telemetry Data:
Viewing Port:
Instrumentation Ports:

12 T/C Channels; R.T.O.S. every 100 seconds
Available through R. F. Loop to Operations Ctr
Door Window (24" x 24")
Number - 2
Dimension - 7" x 5"

AUXILIARY EQUIPMENT

Temperature Conditioner

GN₂ Dehumidification

PAYLOAD MOUNTING

Rack - Front Loading

COMMUNICATIONS

P. A. MITOC System

REFERENCE





Figure 3. Facility 230 Specifications & Configuration



REFRIGERATION SYSTEM
FACILITY 230

Figure 3 (Continued). Facility 230 Specifications & Configuration

The data from facility 237 (see Figure 4) shows temperature rises above ambient generally higher than the results from the standard atmosphere data. Apparently this is due to reduced conduction and convection. The chamber walls were maintained at -10°C with no airflow.

Examining the data for one atmosphere, it can be seen that the thermostat temperature was 12 and 45 degrees above ambients of $+22$ and -55 degrees, respectively. Since the thermostat on/off temperatures are 0 and $+4$ degrees respectively, some estimation can be made of the ambient temperatures during which the heaters will operate. If the recorder is allowed to run until stabilized at 22°C , the ambient temperature could be lowered to approximately $0 - 12 = -12^{\circ}\text{C}$, before the heaters would begin cycling, with a very low duty cycle. If the ambient temperature was now lowered to $+4 - 45 = -41^{\circ}\text{C}$, the heaters would be at the point of being on all the time (high duty cycle). Note that if the recorder was cold soaked (no heater or recorder power connected) between 0°C and -12°C , the application of all power should result in the heater coming on long enough to warm the thermostat and then shutting off, with no cycling.

In the graphs following time increases from left to right; estimated accuracy of temperatures is \pm one degree C.

ACKNOWLEDGMENTS

Thanks to C. Klotz, S. Costa and R. Haney for their technical direction during these tests.

FACILITY NO. 237

MFG: Stokes, Division of Pennsalt Chemicals Corporation

CHAMBER SIZE

Nominal Working Dimensions
Nominal Volume:

7' Dia. x 8' Long (213 cm Dia x 244 cm Long)
305 Cubic Feet (8.5 cu.m.)

VACUUM SYSTEM

1 - 32" Dia. Diffusion Pump:
1 - Mechanical Pump:

40,000 lit/sec
300 std cfm (142 lit/sec)

THERMAL SYSTEM

Heat Transfer Fluid:
Temperature Range:

GN₂ - LN₂
GN₂ Mode - -140°C to +100°C
LN₂ Mode - -190°C

Thermal Control Medium:

Cooling - LN₂

Heating - Electric Heaters

Shrouds:

Material - Aluminum (Traced Tube on Sheet)

Finish - Cat-A-Lac Flat Black

Heat Load Capacity:

15 KW

PAYLOAD MOUNTING

Two rails running length of chamber
86" Long x 45" between rails
Upper support rail on vertical centerline for supporting payload.

INSTRUMENTATION

Data Central:

136 T/C and 44 T/M Channels:

R.T.O.S. printouts every 100 seconds

Telemetry Data:

Available through R.F. Loop to Operations Ctr.

Vacuum Measurement:

Alphatron 760 to 10⁻³ Torr

Ion Gauge 10⁻⁴ to 10⁻⁹ Torr

Contamination Measurement:

LN₂ Coldfinger available to collect
condensable materials

Viewing Port:

12" Diameter located on door at vertical and
horizontal centerline of chamber. Also used
for solar capability

Instrumentation Ports:

Number - 6

Dimensions - 11" Diameter






Figure 4. Facility 237 Specifications & Configuration




VACUUM SYSTEM FACILITY 237





THERMAL SYSTEM FACILITY 237


Figure 4 (Continued). Facility 237 Specifications & Configuration

Temperature Vs. Time
-55°C, 1 ATM Ambient











Final Temperatures (All Negative)

| | |
|---|------|
| A | 9.8 |
| B | 5.0 |
| C | 6.5 |
| D | 16.0 |
| E | 10.6 |
| F | 38.3 |
| G | 31.5 |
| H | 21.6 |
| I | 23.6 |
| J | 14.3 |
| K | 24.4 |
| L | 19.3 |
| M | 48.3 |

Temperature Vs. Time
+55°C, 1 ATM Ambient








Final Temperatures


| | |
|---|------|
| A | 64.1 |
| B | 69.6 |
| C | 68.7 |
| D | 62.4 |
| E | 67.3 |
| F | 59.1 |
| G | 59.5 |
| H | 60.4 |
| I | 58.6 |
| J | 60.2 |
| K | 59.1 |
| L | 64.2 |
| M | 55.6 |

Temperature Vs. Time
-10°C, 75000' (28 mm) Ambient









Final Temperatures

| | |
|---|------|
| A | 16.6 |
| B | 27.2 |
| C | 25.1 |
| D | 22.2 |
| E | 8.0 |
| F | 6.5 |
| G | -4.1 |
| H | 7.9 |
| I | 10.3 |
| J | 8.3 |
| K | 14.9 |
| L | 5.3 |
| M | -0.4 |

| | | | |
|--|--|---|-------------------|
| 1. Report No. NASA TP-1709 | 2. Government Accession No. | 3. Recipient's Catalog No. | |
| 4. Title and Subtitle MARS 1414 Recorder Environmental Tests | | 5. Report Date August 1980 | |
| | | 6. Performing Organization Code 743 | |
| 7. Author(s) David Langjahr | | 8. Performing Organization Report No. 80F5124 | |
| 9. Performing Organization Name and Address Goddard Space Flight Center Greenbelt, Maryland 20771 | | 10. Work Unit No. | |
| | | 11. Contract or Grant No. | |
| 12. Sponsoring Agency Name and Address National Aeronautics and Space Administration Washington, D. C. 20546 | | 13. Type of Report and Period Covered Technical Paper | |
| | | 14. Sponsoring Agency Code | |
| 15. Supplementary Notes | | | |
| 16. Abstract <p>This technical paper describes environmental testing and presents the data of the Modular Airborne Recording System (MARS) 1414. This paper is intended to be used as a tool for analysis of this recorder. The preliminary data marks a starting point for more complete thermal testing in the future. The unit was operated at the limits specified by the manufacturer (Bell and Howell), that is $\pm 55^{\circ}\text{C}$ at one atmosphere, -10°C at 75,000 feet (28mmHg) at the other. Temperatures at 13 locations on the unit were monitored and plotted against elapsed time. From the test results, some estimation can be made of ambient temperatures in which the heaters will operate and shut off. This data is sufficient to complete a preliminary analysis of the MARS 1414 Recorder, and to design further tests in which to obtain greater results and more thorough analysis.</p> | | | |
| 17. Key Words (Selected by Author(s)) MARS Airborne Recording System Environmental Tests | | 18. Distribution Statement Unclassified - Unlimited Subject Category 35 | |
| 19. Security Classif. (of this report) Unclassified | 20. Security Classif. (of this page) Unclassified | 21. No. of Pages 28 | 22. Price* A03 |

*For sale by the National Technical Information Service, Springfield, Virginia 22161.

National Aeronautics and
Space Administration

Washington, D.C.
20546

Official Business

Penalty for Private Use, \$300

THIRD-CLASS BULK RATE

Postage and Fees Paid
National Aeronautics and
Space Administration
NASA-451



1 1 1U,D, 082280 S00903DS
DEPT OF THE AIR FORCE
AF WEAPONS LABORATORY
ATTN: TECHNICAL LIBRARY (SUL)
KIRTLAND AFB NM 87117

NASA

POSTMASTER: If Undeliverable (Section 158
Postal Manual) Do Not Return